



Fire Barrier Combustible Pipe Device

Declaration of Performance

N° 3M FB CPD 1121-CPR-JA5017

according to Annex III of Regulation (EU) No 305/2011

1. Unique identification code of the product-type:

3M™ Fire Barrier Combustible Pipe Device

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):

BN12345
BN = Batch Number
12345 = Manufacturing Digit

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

3M™ Fire Barrier Combustible Pipe Device is used as a system to reinstate the fire resistance performance of flexible and rigid wall and rigid floor constructions where they are penetrated by various combustible pipe services.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

3M Nederland B.V
Industrieweg 24
2382 NW Zoeterwoude
The Netherlands
<http://www.3m.com/>

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

No Performance Determined

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

No Performance Determined

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

3M™ Fire Barrier Combustible Pipe Device has been issued an European Technical Approval (ETA-13/1062) by the notified body Warrington Certification Limited on the basis of ETAG 026-2 (Guideline for European Technical Approval of Fire Stopping and Fire Sealing Products Part 2 Penetration Seals: 2008-01-01

Notified Body, Warrington Certification Limited, NB 1121, performs the initial inspection of manufacturing plant and of FPC and issued the confirmation of constancy of performance No 1121-CPR-JA5017

9. Declared performance

Essential Characteristics	Performance	Test Standard	Harmonised technical specification
Reaction to Fire	Class E	DIN EN 13501-1	ETAG 026-2
Resistance to Fire	Up to EI 120	EN 1366-3 :2009	
Dangerous Goods	-		
Safety in Use	ETA 13/1062		
Hygiene, Health and the Environment	ETA 13/1062		
Energy, Economy and Heat Retention	-		
Durability and Serviceability	Z ₁		

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Christoph Küsters
Senior Technical Manager

Neuss, 01.11.2014

For further information:

3M United Kingdom PLC 3M House, 28 Great Jackson Street, Manchester, M15 4PA	Product Information : Tel 0870 60 800 50 Fax 0870 60 700 99	3M Ireland Limited The Iveagh Building The Park, Carrickmines Dublin 18, Ireland	Customer Service : Tel (01) 280 3555 Fax (01) 280 3509
--	---	--	--

Important Notice

All statements, technical information and recommendations contained in this document are based upon tests or experience that 3M believes are reliable. However, many factors beyond 3M's control can affect the use and performance of a 3M product in a particular application, including the conditions under which the product is used and the time and environmental conditions in which the product is expected to perform. Since these factors are uniquely within the user's knowledge and control, it is essential that the user evaluate the 3M product to determine whether it is fit for a particular purpose and suitable for the user's method or application. All questions of liability relating to this product are governed by the terms of the sale subject, where applicable, to the prevailing law



3M Nederland B.V
 Industrieweg 24
 2382 NW Zoeterwoude
 The Netherlands

13

3M™ Fire Barrier Combustible Pipe Device

DoP 3M FB CPD 1121-CPR-JA5017

ETA-13/1062

3M™ Fire Barrier Combustible Pipe Device is used as a system to reinstate the fire resistance performance of flexible and rigid wall and rigid floor constructions where they are penetrated by various combustible pipe services.

Reaction to Fire	Class E acc. to EN 13501-1
Resistance to Fire	Up to EI 120 acc to EN 1366-3 :2009
Dangerous Goods	-
Safety in Use	ETA 13/1062
Hygiene, Health and the Environment	ETA 13/1062
Energy, Economy and Heat Retention	-
Durability and Serviceability	Z ₁

Confirmation of conformity and performance described in the above mentioned ETA by
 Warrington Certification Limited, NB 1121

Important Notice

All statements, technical information and recommendations contained in this document are based upon tests or experience that 3M believes are reliable. However, many factors beyond 3M's control can affect the use and performance of a 3M product in a particular application, including the conditions under which the product is used and the time and environmental conditions in which the product is expected to perform. Since these factors are uniquely within the user's knowledge and control, it is essential that the user evaluate the 3M product to determine whether it is fit for a particular purpose and suitable for the user's method or application. All questions of liability relating to this product are governed by the terms of the sale subject, where applicable, to the prevailing law